

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.743

Dated: 26/06/2025

It is certified that an inspection team headed by AKSHAY KUMAR (Name of Officers with designation) from J.En PHED BEAWAR..... Inspected the

DELHI PUBLIC SEC. SCHOOL, GOPAL SAGAR, KHARWA.....

(Name & Address of the school) on 10/06/2025.(date of inspection) and on the basis of Water Test

Report (Attached) bearing no .....451..... dated.....26/06/2025.....

of.....PHED REGIONAL LAB AJMER.....(PHED Lab)certified that the

DELHI PUBLIC SEC. SCHOOL, DIST. BEAWAR.....( Name of school)

has safe drinking water facilities for the students and members of staff of the institution. School is

also maintains the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ...25/06/2028.

  
**Executive Engineer**  
**PHED Division Beawar**

Signature with Seal: .....  
Name : ANAND SHARMA.....  
Designation : Executive Engineer.....  
Name & Address of the Office/Department:PHED  
BEAWAR

To

DELHI PUBLIC SEC. SCHOOL  
G.P. KANAKHERA, DIST. BEAWAR  
(Name &Address of the Institution)

**OFFICE OF THE SUPERINTENDING CHEMIST**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT REGIONAL LABORATORY, AJMER (Raj)**  
**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

No. Lab/Tech / 2025-26/ 451

Date: 26.6.2025

To,  
 Principal  
 Delhi Public Secondary school  
 Gopal sagar, Kharwa

**Not for Legal Purpose**

**Sample was not Collected  
 by Laboratory**


District: Beawar  
 Block: Masuda

Reference: Your Letter No DPSS/0056/2025-26 Dated 26.06.2025  
 Sample Collected by :- Dhanendra Dosi

Date of Receipt :- 26.06.2025

Lab Sample No.		IS10500:2012		P-30
Source :		Desirable Limit as per IS10500:2012	Permissible Limit in absence of alternate source	Storage Tank (Cane Water)
Source Location:				Delhi Public Secondary school
Town / Village				Kharwa
Date of Collection→				26.06.2025
Date of Examination→				26.06.2025
Test Parameter↓				Results↓
1	pH Value	6.5 - 8.5	No Relaxation	7.85
2	Turbidity (NTU) Max	1	5	0.2
3	Colour (Hazen Units), Max	5	15	Nil
4	Odour	Aggreable		Aggreable
5	Total Alkalinity (as CaCO <sub>3</sub> ) mg/l, Max	200	600	70
6	Total Hardness (as CaCO <sub>3</sub> ) mg/l, Max	200	600	60
7	Chlorides as Cl <sup>-</sup> mg/l, Max	250	1000	30
8	Fluorides as F <sup>-</sup> mg/l, Max	1.0	1.5	0.40
9	Nitrate as NO <sub>3</sub> <sup>-</sup> mg/l, Max	45	No Relaxation	2
10	Total Dissolved Solids(T.D.S.) mg/l, Max	500	2000	230
11	Residual Chlorine	0.2	1.0	Nil
		Applicable only when water is Chlorinated		

Note: 1. The sample was not collected by this laboratory.  
 2. This Report is not for legal Purpose.

  
 (Dr. Archana Mathur)  
 Superintending Chemist  
 P.H.E.D. Regional Lab., Ajmer